මගේ අංකය) බොහු මුහ. My Number

இதே மூறைக் உறது இல். Your Number



තැ.පෙ.අංකය-57 තිරුනෙල්වේලි , යාපනය

த.பெ. எண் - 57, ஐருநெல்வேலி, யாழ்ப்பாணம்.

දුරකටිනය: 021-2222483 நொலைபேசி:021-2222006 Telephone: 021-2222644 UNIVERSITY OF JAFFNA, SRI LANKA.

P.O. Box - 57, Thirunelvely, Jaffna.

Finance Branch, University of Jaffna 10.04.2023

Dear Sir/ Madam,

MINUTES OF THE PRE-BID MEETING OF SUPPLY & INSTALLATION OF DIESEL GENERATOR AT UNIVERSITY OF JAFFNA

Tender Ref: UJ/F/NCB/01/2023

As per the pre bid meeting held on 10.04.2023 at 10.00 a.m., it has been decided to made the following changes as given below.

Description	As Published	Revised as	
13.2	13.2 Supplier should have minimum 5 years' experience in handling large projects. They should have supplied minimum of 1 project of minimum 50 million Rupees each during last 2 years. Copies of purchase orders need to be attached with the tender.	13.2 Supplier should have minimum 5 years' experience in handling large projects. They should have supplied minimum of 1 project of minimum 15 million Rupees each during last 2 years. Copies of purchase orders need to be attached with the tender.	
Generator Control panel	The capacity of the circuit breaker and the ATS shall be at least 400 Amps	The capacity of the circuit breaker and the ATS shall be at least 250 Amps	
Fuel tank	Minimum capacity of 500 Littic.	Minimum capacity of 250 - 400 Littic	
Installation. Automation & Commissioning	Necessary Armored Cables and Control panel, Including changeovers for automation of Generator power.	Necessary Armored Cables and Control panel, Including changeovers for automation of Generator power. Armored Cables Size: 70 millimeter Length: 5-6 meter	
	Generator Control panel Fuel tank Installation. Automation &	13.2 Supplier should have minimum 5 years' experience in handling large projects. They should have supplied minimum of 1 project of minimum 50 million Rupees each during last 2 years. Copies of purchase orders need to be attached with the tender. Generator Control panel Generator Control panel The capacity of the circuit breaker and the ATS shall be at least 400 Amps Fuel tank Minimum capacity of 500 Littic. Installation. Automation & Commissioning changeovers for automation of	



Page 44 - Price schedule

As Published

No	Description of the Item	(1)	(2)	(3)	(4)	(5)
		Qty	Unit Price	VAT	Unit Price with VAT	Total
1	Diesel Generator	01 No				

Revised as

No	Description of the Item	(1)	(2)	(3)	(4)	(5)
		Qty	Unit Price	VAT	Unit Price with VAT	Total
1	Diesel Generator	01 No				
2.	Supply & Installation Charges	01 Lot				